



Pharmatech

Pharmatech Process Equipments

COMMISSIONING REPORT

DOC. NO. : F.SER:04

Rev. No : 00

Rev. Date : ---

DATE : 19/1/2022

CUSTOMER NAME :	M/S Indian Immunologicals Ltd (Hydrabad)	
CONTACT PERSON :	P. Sukuman.	
DESIGNATION :	Manager.	
EQUIPMENTS :	200L Mixing vessel	
JOB NO. :	20-21/57/0372	
ATTENDED BY :	Pabani Harshik.	
COMMISSIONING STARTED ON :	17/1/2022	COMPLETED ON : 19/1/2022

ACTIVITY DONE : Commissioning of 200L mixing vessels completed. checked all the input and outputs at Hmi found ok. All pneumatic valve working from Hmi found ok. All Auto cycle cycle/stop left filling, blanketing, mixing, Ingredients addition Testing & trial completed. Some all programming related changes done as per client requirement some verify by client. Magnetic stirrer working smoothly. Level cell calibration done. User management verify by client found ok. All operation training given to production department. Safety valve set pressure around 2.0 bar set as per client requirement. All cycle trial taken with paintouts found ok. All the above trial done in presence of JIL persons found satisfactory. IQ-aq and Sat Protocol also completed as per document PPE kindly suggest please maintain a steam pressure less than 2.0 bar.

REMARK BY CUSTOMER IF ANY :

Are you Satisfied by Commissioning ? : Yes No

For, Pharmatech Process Equipments	For, Customer
Name : Pabani Harshik.	Indian Immunologicals Ltd.
Designation : Engg. Service	Name : P. Sukuman
Signature : H. Pabani.	Designation : Manager
	Signature : P. Sukuman, 19-01-22.