



INSTALLATION **SERVICE REPORT**

BNG/22-23
No.: **9134** Date: **24/1/2023**

Customer Address : TO Contact Person : CHARGEABLE
Contact No. : AMC
 GP

Human Biologicals Institute

E-mail : _____
Complaint Recd Date : ooty Time : _____ Complaint No / Indent No. : 0079

Unit Rating : 20kVA/220V Ver : 305 SL No : MY2212069
Unit Configuration : **SA/PRS / HSB / WITH LOGIC** UNIT GP : _____ Years

Battery : AH : 10 Make : Quat No. of Batteries : 20
 TUB AUT MFB

Battery Configuration : **SA/PBB / CBB** BATT GP : _____ Years

Accessories / Others : _____

Nature of Complaint : New Installation

INCOMING VOLTS : 1PH P-N : 230V N-E : 0.0V P-E : 230V
3PH R-Y : 429V Y-B : 429V B-R : 429V N-E : 0.0V

CHARGING VOLTAGE : 270V CHARGING CURRENT : _____ AT _____ V

INVERTER O / P VOLTAGE : 230V LOAD CURRENT : _____

TYPE OF LOAD ON INVERTER: Computers : Computer Nos, Printers : _____
Others : (Specify) _____

NATURE OF FAULT OBSERVED : New Installation

ACTION TAKEN : Now Installed a new 20kVA/220V
(Remarks if Any) : Online UPS & 20 nos batteries 10AH SMF
along with battery stand now the unit is
working normally

This is to Certify that your Engineer Mr. Shivraj P
has attended the installation / complaints and the system is working in good condition.

Service Engineer Sign : [Signature]
Date : 24/1/2023

Time In : _____ Time Out : _____ Customer's Sign. & Seal