



DAIKIN AIRCONDITIONING INDIA PVT. LTD.

Customer Service Report

Service Branch : **Hyderabad**

Toll Free
1800-102-9300
1800-22-9300 (From MTNL/BSNL)

| | | | | |
|------------------|------------|-----------------------|--|-------------------------------|
| Registration No. | 191012028 | Type of Service : AMC | <input type="checkbox"/> Commissioning | Chiller Model : W5088F |
| Date | 19/11/2022 | Warranty | <input type="checkbox"/> Other | Serial Number : 101 |
| Customer Name | Hyderabad | Nature of Complaint : | | |

Address : **Backhills, Hyderabad**

Chiller commissioning.

Description of Troubleshooting and Works Carried out :

Chiller has been commissioned successfully.
 Due to high load, head tuning is pending.
 Attached the same to customer.

Please fill these the troubleshooting documents for model.

Daikin Engineer's Remarks :

Customer's Remarks :
 The chiller is working properly. The head tuning is pending. The troubleshooting documents are attached for the same.

| | | | | | | |
|--------------------------|---|----------|-------|------|------------------------------|--------------------------|
| Work Status : | Completed | Spares : | Reqd. | Used | Service Engineer Name : | A. Dinesh |
| | <input type="checkbox"/> Y <input type="checkbox"/> N | | Reqd. | Used | Reporting Date & Time : | 12/11/22 12:10:00 |
| Awaiting for Spares | <input type="checkbox"/> Y <input type="checkbox"/> N | | Reqd. | Used | Job Completion Time : | 12/11/22 |
| Awaiting Customer Action | <input type="checkbox"/> Y <input type="checkbox"/> N | | Reqd. | Used | Service Engineer Signature : | <i>[Signature]</i> |

To be filled if chiller is Operational:

| | | | | | |
|---------------------------------------|--------------|------------|---|-------------|---------|
| Set Point Leaving Water | 41.1 | °C / °F | Discharge Temperature (close liquid injection if Centrifugal) | 41.1 | °C / °F |
| Evaporator Entering Water Temperature | 50 | °C / °F | Discharge Superheat | 21.8 | °C / °F |
| Evaporator Leaving Water Temperature | 59 | °C / °F | Saturation Evaporator Temperature | 59 | °C / °F |
| Condenser Entering Water Temperature | 49 | °C / °F | Saturation Condensing Temperature | 47 | °C / °F |
| Condenser Leaving Water Temperature | 57 | °C / °F | Liquid Line temperature (measure if reading not available on Display) | 41.7 | °C / °F |
| Suction Pressure | 5.1 | Kpa / PSIG | Suction Temperature | 41.7 | °C / °F |
| Discharge Pressure | 26.17 | Kpa / PSIG | Suction Superheat | 5.7 | °C / °F |
| Net Oil Pressure | 11.7 | Kpa / PSIG | Evaporator Refrigerant Level | 0 | |
| Oil Level | 0 | | Condenser Refrigerant Level | 0 | |
| Ambient Temperature | 41.1 | °C / °F | Compressor Amperage | 11.7 | Ampere |
| Refrigerant Type | R134a | | | | |

I certify that the work has been completed to my satisfaction

Customer Signature : *[Signature]*

Customer Name & Designation : **K. R. Reddy / Sr. Manager**

For Service Quality feedback, suggestions or complaints about Service, kindly mail us at cs@daikinindia.com