



Pharmatech

Innovative Processing solutions

Pharmatech Process Equipments

COMMISSIONING REPORT

DOC. NO. : F:SER:04

Rev. No. : 00

Rev. Date : 01/07/2013

DATE : \_\_\_\_\_

CUSTOMER NAME :	M/s. Indian Immunological Ltd. - Hyderabad - Giachibovid	
CONTACT PERSON :	P. Suresh	
DESIGNATION :	Executive	
EQUIPMENTS :	50 Ltr (Gross) Blending vessel.	
JOB NO. :	16-17/SJ/00325	
ATTENDED BY :	Mr. VIPUL DARJI	
COMMISSIONING STARTED ON :	02-03-2017	COMPLETED ON :

ACTIVITY DONE : Commissioning of 50ltr blending vessel completed with fully satisfactions.

- checked all the inputs/outputs via maintenance made from HMI found OK. Checked all the press. valves ON/OFF
- Completed the load-cell calibration with given its training to the IIL persons.
- Completed IQ/OQ as per documents. checked stirrer motor trials with min. to max. RPM with water found working smoothly.
- checked all the semi auto trials like heating, chilling, mixing, transfer, CIP, leak test & SIP with actual utilities and found all the trials completed as per its logic & set parameter.
- Trial related fully training of operation given to IIL persons.
- Completed the pH sensor calibration found ok.
- overall completed commissioning work with satisfaction and vessel is handed over to client.

REMARK BY CUSTOMER IF ANY :

Screen shots to be provided related to login, operation, process cycles etc.

Are you Satisfied by Commissioning ? :  Yes  No

For, Pharmatech Process Equipments	For, Customer
Name : Mr. Vipul Darji.	I.I.L - Hyderabad.
Designation : Sr. Engr. - service	Name : P. Suresh
Signature :	Designation : Executive
	Signature :