

FSR Number:		VERINBLRL047.021121.I.2			Dated: 02-11-2021			
		<input type="checkbox"/> AMC		<input checked="" type="checkbox"/> WARRANTY		<input type="checkbox"/> POST WARRANTY		
		Product:			Power			
Type of Service:	<input checked="" type="checkbox"/> I&C	<input type="checkbox"/> PM	<input type="checkbox"/> FAIL	<input type="checkbox"/> CORRECTIVE	<input type="checkbox"/> TRAINING	<input type="checkbox"/> TECH.	<input type="checkbox"/> COURTESY	<input type="checkbox"/> OTHER
Customer:	M/S. Indian Immunologicals Limited.			Engineer's Name:	RAMAN			
Site Address:	Survey No: 281-284&321 ,Biotech Park Phase III,			Employee Code:	7059			
	Karkapatla, Markook Mandal, Siddipet Dist, Telangana -			Phone Number:	7400086903			
	502281, India			Call ID Number:				
Customer Contact:	MR.Peddi Reddy ; 9959050359			Region:	SEZ_HYDERABAD			
Date of Complaint:	2/11/2021			SO/Contract Number:				
Time of Complaint:	10:00			Channel:				
Complaint/Fault Reported:	60KVA UPS I&C							

Reporting Date/Time:	2/11/2021	Manhours Idle/Stay:	hours minutes	Time of Completion:	17:30
Manhours Travelling:	2 hours 0 minutes	Manhours Onsite:	4 hours 0 minutes	Total Manhours:	6 hours 0 minutes

System Details

	Model	Rating	Serial Number
1	HIPULSE U	60KVA	202102HU4844
2			
3			
4			
5			
6			
7			
8			
9			
10			



Observations / Comments / Recommendations / Suggestions / Work Done

Checked the UPS physical conditiona and all cables terminations found ok.
 Hipulse U model 60KVA UPS with Quanta SMF 12V/120AH-32no's - 2sets of Batteries (Batteries APS scope) Installation & Commissioning done sucessfully.
 UPS tested with no load at present Customer load not connected.
 Output Voltage : 405V, as per the customer requirement.
 Bypass Enabled

Spare Parts Recommendation

	Part Code	Description	Quantity	Price
1				
2				
3				
4				
5				

Service to be billed:		Total Price:	
-----------------------	--	--------------	--

Customer's Remark and Signature	Engineer's Remark and Signature	Operations Manager's Remark
The above job was carried out and completed to our satisfaction. The equipment is working satisfactorily. We agree to pay the charges as indicated.		
		

For Queries, please contact our Customer Care Center
 T: 1800 209 6070
 Vertiv Energy Private Limited