



POWER-INN SYSTEMS & CONTROLS

H.No. 7-1-217/D, DK Road, Near Nature Cure Hospital,
Ameerpet, Hyderabad - 16. Mobile: 9951432687, 9010201211
reddy@kbpowerinn.com, Website : www.powerinnups.com

INSTALLATION / SERVICE REPORT

Customers Name & Address	Contact Person / Phone No.	Date
M/S. IIL HA-34, Gochi Bazar, HYD.	M. Radha Krishna	24/11/17

Model Make : **SYSTEM DETAILS** 1) Warranty 2) A.M.C. 3) Chargeable

Sl. No.	Rating / D.C. Bus	BTY Type / Make	BTY AH / Volts / Qty	Phase
895 24/11/2017	6kva/120vdc	SMP/EXIDE	26/12/10	I/P.....1φ..... O/P.....1φ.....

Nature of Problem : 6kva ops delivery & installation.
(New UPS)

Defect Found on Inspection : ops installed.

Rectification Undertaken : ops ok and working properly in the main and Battery mode.

Spares Used		Parameter Readings			
		(V & I)	R	Y	B
		A.C. I/P (V)	242V		
		A.C. O/P (V)	230V		
		A.C. O/P (I)			

Job	Date	Time	IP N to E
Started	24/11/17		: 0.1V
Finished	24/11/17		: 0.1V
			D.C BUS (V) : 136vdc
			BTY Charging (I) : 3 amp.

Customer's Comments : P.O. NO:- 4511002334 ; Dated: 24-Nov-2017
UPS kept under observation.

Engrs. Name : S. Seethaiah
Engrs. Sign. : S. Seethaiah
M. Radha Krishna
24-11-17
Customer's Sign. & Seal