

M/s. KANYAKA PARAMESHWARI ENGG. LTD., HYD.

COMMISSIONING/ INSTALLATION/ SERVICING CALL REPORT

A		B	
Customer Name: <u>M/s. HUMAN BIOLOGI-</u>		Ref. No.: <u>ITL/00TY-TN</u>	Dt: <u>16-01-2023</u>
Address: <u>- CAL INSTITUTE TAMIL</u>		Tr. Sl. No.: <u>KP-PT-463/</u>	KVA: <u>800 x 02</u>
<u>NAADU, 00TY-TN.</u>		Make: <u>KPEL - 464</u>	Yr. of Mfg. <u>11/2022</u>
Reporting Person Mr./Mrs. <u>JESURAJ SIR</u>		Call Category: <u>Under warranty / Out-of-warranty</u> <input checked="" type="checkbox"/>	
Phone No.: <u>7598213536</u>		Service / <u>CALL - SIDHU - 8106846138</u>	
Details of Complaint: <u>INSTALLATION</u>		Attended By: <u>R. SIDHU. BIRADAR</u>	
C		D	
Observation		Work Done	
<u>Distribution Transformer</u>		<u>Distribution Transformer 800kva</u>	
<u>SL. NO.: - KP-PT-463</u>		<u>02 no's radiator fitting, conser-</u>	
<u>SL. NO.: - KP-PT-464</u>		<u>-vator, fitting, oil filling and</u>	
<u>800 KVA with OLTC.</u>		<u>OLTC TO RTDC panel wiring</u>	
<u>Installation work.</u>		<u>work is completed.</u>	
<u>AVR setting's</u>		<u>800 kva 02 no's Transformer</u>	
<u>Raise :- 420V</u>		<u>Charged.</u>	
<u>Lower :- 433V</u>		<u>800 kva 02 no's Transformer</u>	
<u>voltage :- 430V</u>		<u>load also given</u>	
<u>Tap no :- 05</u>		<u>finally 800 kva Both Transfo-</u>	
<u>Time delay :- 60 sec</u>		<u>-mer running in good</u>	
<u>oil level in conservator</u>		<u>condition.</u>	
<u>up to above 1/2 level.</u>		<u>Three phase and single phase voltage</u>	
<u>OLTC side also same</u>		<u>Ry - 430 v Rn - 220 v</u>	
<u>oil level maintain.</u>		<u>YB - 430 v YN - 218 v</u>	
<u>Checked found OK.</u>		<u>BR - 431 v BN - 220 v</u>	
Date of Reporting: _____ Time: _____		Date of Completion: _____ Time: _____	
E		F	
Material Used		Material Returned	
<u>1) Multimeter - 01</u>		<u>1) Multimeter - 01</u>	
<u>2) Megger - 01</u>		<u>2) Megger - 01</u>	
<u>3) Tool Kit set - 01 set</u>		<u>3) Tool Kit set - 01 set</u>	
G			
Customer Remarks			
<div style="border: 1px solid black; padding: 5px; width: fit-content; margin: auto;"> Indian Immunologicals Ltd, Human Biologicals Institute Kozhipannai, Pudumund PO Udhagamandalam-643007 Ph No: 94492 2442196 2441928 </div>			
<u>R. Jesuraj</u> 16.01.22. Customer Signature with Seal		<u>SIDHU. RAYON</u> Service Engineer for, KANYAKA PARAMESHWARI ENGG. Ltd.	

R. Jesuraj

8106846138