

INSTALLATION / SERVICE REPORT

Cold Room Standby units, Downstream Lab, Eaco cold room.



1050/51, T.H. Road, Kaladipet, Chennai - 600 019.
Ph : 044-2599 4123

For office use
 To bill
 Not to bill

M/s. INDIAN IMMUNOLOGICALS LIMITED. Date: 09/03/13
Raksha Puram, Gachibowli Post Ref: 102/14.12.12
Itidara Sad - 500 032. No.: 718

Equipment: Supply of Standby unit Refrigeration. Unit Model No: ICCH Unit Sl. No. / Comp Sl. No.
 1. CR221K6M
 Call received on: Mr. SURESH. Call Attended by: Mr. SURESH 2. FAA 0232378
 3. 0232379.

	Date	Time	Materials Use	Qty.
Arrival at site	-	-	Copper pipe, Refrigerant, Selsalt, hose & SUS zero, Aluminium	
Work started at site	-	-		
Work completed at site	-	-		
Departure from site	-	-		

Section Pr	Psig	50	50	SUPPLY & Installation of Standby unit Refrigeration system to deg. maintain temperature for 1 set at stand by unit in Eaco cold room 1 set at standby unit at Blue star cold room M. Sub Technician Signature
Discharge	Pr Psig	250	250	
Current	Amps	5.6	5.8	
Voltage	Volts	220	220	
Ambient	Temp	30°C		
For Pk/ Ductable /CP				
Coil Entering		—		
Coil Leaving		—		
Air Colled CPS	Current			
CT	OK	Not		

For Cold Rooms and Refrigerated Trucks The equipment has installed to my our Satisfaction I/We agree to pay the charges if any
 Other Comments (if any) :
 Room Temp +4°C
 Setting Temp +4°C to 7°C
 Room Leakages —
 Date: 9-03-13 Customer's Stamp & Signature