



FIELD SERVICE REPORT

Tel. : +91 866 6622 751 / 2570 792 Fax : +91 866 6622 752

Customer's Name & Address		M/S. Indian Immunologicals Limited, Rakshapuram, opp. stadium, Gachibowli.	
Person contacted (Name & Designation)		Mr. Radha Krishna	
Engine Serial No.	Engine Model	Alternator Serial No.	Alternator Model
85013525	DSE-60-64	N22H330043	SZL10-641
Control Panel : AMF/STD	Hourmeter Reading	Complaint Received on	Attended on
Sr. No. 01/PAB1/2209637	-	-	28/11/22
Switchgear Type	Customer's Contact No.	Gov. Type	AVR. Make & Type
Make : Schwab Rating :	-	PCC 3.3	PCC 3.3

Customer's Complaint

Pre-commissioning of 1x2000 kVA D.G.

Description of work done

Visited the site to pre-commissioning the 1x2000 kVA D.G. before start the D.G. checked the following necessary checks

- 1) checked the lube oil level. found ok
- 2) checked the coolant level and leakage. found ok.
- 3) connected the Engine and alternator harness to the D.G. controller (PCC 3.3)
- 4) connected the batteries and checked the necessary parameters & settings in the PCC 3.3.
- 5) Filled Diesel up to 500 ltr and checked the leakage.

	Performance Checks	
	1. Water Temp.	40°C
2. Lube Temp.	33°C	
3. Lube Pressure	583 kpa	
4. High idle RPM	1700	
5. Full Load RPM	-	
6. Battery SG	-	
7. Battery V	25.9	
8. KWH Reading	-	
9. KW Reading	-	
10. Amperes	no load.	

Service Representative Name B. SRINU Date Sign. B. Srinu	Customer's Remarks D.G. set pre-commissioning activity done and found ok Sign. M. T. Ch... 28.11.22	Time In
		Time Out

8790902992.