



ESENNAR TRANSFORMERS PVT. LTD.


(SERVICING WORK REPORT)

SWR NO

DATE OF COMPLAINT	10/02/2022
1 DATE OF CHECKUP COMMISSIONING	
2 COMPANY NAME	M/s. Indian Ironworks Ltd
ADDRESS & PHONE NO	Coimbatore
3 RATING OF TRANSFORMER (kVA)	2000 kVA
4 VOLTAGE RATIO PRIMARY	33000
SECONDARY	433
5 TAP CHANGER	OLTC <input checked="" type="checkbox"/> OFF <input type="checkbox"/>
6 SL.NO	ET2-7331
7 YEAR OF MANUFACTURE	2022
8 COMPLAINT	unloading & installation of oil filled transformer
9 ACTION INITIATION	Transformer installation completed and commissioning pending.
10 SOLUTION	TTR unloading at and TTR Radiator fitting and tightening at oil filling and air released at TTR oil level at both sides. Insulation fitting at. TTR Ready to change No leakage.
11 BILL VALUE	Will be sent by Courier <input type="checkbox"/> Free of Cost <input type="checkbox"/>
12 CUSTOMER FEED BACK	Excellent Good Bad
i SERVICE	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
ii PROMPT RESPONSE	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
iii ENGINEERS BEHAVIOUR	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
iv COMPLETION OF JOB	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
PERSON NAME	J. Vidya Sagar Reddy
DESIGNATION	Deputy Manager
PHONE NO	964395333
CUSTOMER SIGN & DATE	<i>[Signature]</i> 10-02-22

For Esennar Transformers Pvt Ltd

Service Engineer



[Signature]