

## HYDRAULIC PRESSURE TESTING CERTIFICATE

MARS/HYD/IILK/46/22-23

13.07.2022

To,  
**M/s INDIAN IMMUNOLOGICALS LIMITED**  
**Survey NO. 281-284&321, BiotechparkphaseIII,**  
**Karakapatla Markook Mandal, Siddipet Dist.,**  
**Telanagana -502281 India**

Kind Attn: Mr. BALAJI / RAMAKRISHNA

Dear Sir,

**Sub: - Hydraulic Pressure Testing of Fire Hydrant System at IIL Karakapatla, Hyd**  
**Ref: - You're Work Order/Ref. No. 4511003975 dated: 17.01.2022**

With reference to the above subject we would like to bring to your kind notice, that the above said system is kept for Hydraulic Testing Of left wing for 24 Hrs. at 11 Kg from date& time -06.07.2022 at 5.00p.m – we found 11 Kg. Pressure on 07.07.2022 at 2.00p.m and found satisfactory without any Leakages.

Further we request you to take over above said System with duly sign & seal this document as an acceptance.


However, if you need any further clarification please feel free to call us or write to us.

Thanking you,

For M/s. Mars Fire Safety Sytems



Client Signature & Seal

  
13/07/2022