

COMMISSIONING/ INSTALLATION/ SERVICING CALL REPORT

A		B	
Customer Name: <u>M/s. INDIAN IMMUNO</u>		Ref. No. : <u>4511004582</u>	Date: <u>20/01/24</u>
Address: <u>LOGICAL LTD. JUBLI HILLS</u>		Tr. Sl. No.: <u>KP-PT-765</u>	KVA: <u>800 OLTC</u>
Reporting Person Mr./ Mrs. <u>VIDYA SAGAR SIR</u>		Make: <u>KPEL</u>	Yr. of Mfg: <u>12/2023</u>
Phone No.: <u>9640395333</u>		Call Category: <u>Out of warranty / Under warranty:</u>	
Details of Complaint: <u>800 KVA T/R Insta</u>		Call Service: <u>8106846138</u>	
<u>- Location Work & Charging.</u>		Attended By: <u>R. SIDHU BIRATAR</u>	

C

Observation

Distribution Transformer
800 KVA with OLTC
SL. No :- KP-PT-765
Radiator fitting, oil
filling and OLTC TO RTCC.
panel wiring with 800kva
Transformer charging
work.
AVR setting
raise :-
lower :-
voltage :-
Tap no :-
Time delay :-
Oil filled in conservator
up to 3/4 level.

Date of Reporting : / / Time: :

D

Work Done

Distribution Transformer
800 KVA with OLTC
Radiator fitting, oil filling
OLTC TO RTCC panel
work is completed.
800 KVA Transformer is
successfully charged.
Transformer load is given
Both Transformer and
OLTC is running in
Good condition.
Three/Single phase voltage
RV - RN -
VB - VN -
BR - BN -

Date of Completion : / / Time: :

E

Material Used

01) Multimeter - 01
02) Megger - 01
03) Drilling n/c - 01
04) Tool kit - 01 set


F

Material Returned

01) Multimeter - 01
02) Megger - 01
03) Drilling n/c - 01
04)

G

Customer Remarks



SIDHU Rajendra
Service Engineer
for, **KANYAKA PARAMESHWARI ENGG. Ltd.**
8106846138