

702, tanishka, akurli road,  
kandivalli east, mumbai - 400101  
tel.:+91-22-61776700  
fax:+91-22-61776799  
email:info@adamfabriwerk.com  
www.adamfabriwerk.com



adam™

fabriwerk  
private limited

boundaryless processing systems™  
works: survey no.81. plot a&b. ambad, nashik - 422010





DATE	05/05/2022	CLIENT NAME	INDIAN IMMUNOLOGICALS LIMITED
PROJECT NO.	L019	CLIENT JOB NO.	0810721
PROJECT NAME	KILL TANK (COLLECTION TANK (T03) 2000 LTR , INACTIVATION TANK (T01) 1500 LTR AND INACTIVATION TANK (T02) 1500 LTR		
MEETING AGENDA	MODIFICATION OF HEATING PROCESS IN INACTIVATION CYCLE.		
VISIT PERIOD	04/05/2022 TO 05/05/2022		

Following work had been done for Inactivation Tank (T01) 1500 Ltr and Inactivation Tank (T02) 1500 Ltr VESSEL:

1. Added interlock for closing vent valve during heating also added parameter for the same in BATCH PRODUCTION SETTINGS in IPC.
2. Inactivation cycle has been performed with 122°C set temperature for both Inactivation Tank - T01 1500 Ltr and T02 1500 Ltr, as cycle found satisfactory also checked the report and submitted to the client.

**REMARK FROM CLIENT:**

- (1) SCADA and PLC latest backup shall be provided by Adamfabriwerk
- (2) Inactivation cycle has been performed at 122°C for both T01 and T02 tanks.
- (3) In the printout the values of picro1 (T03) are printed as -0.00, need justification from Adam for negative readings.
- (4) Equipment (Kill Tank) will be under observation, Adam has to support on priority in case of any breakdown.

ADAM FABRIWERK PVT. LTD.- Nashik	INDIAN IMMUNOLOGICALS LIMITED , HYDERABAD
<p>1. Navin Chavan (Software Engineer)</p>  <p>05.05.22</p>	<p>1. P. Ramkrishana</p>  <p>05.05.22</p>
	<p>2. G. Balaji</p>  <p>05.05.22</p>
	<p>3. G. Janardhan</p>  <p>05.05.22</p>