

MINUTES OF MEETING		
Bright Pharma Engineering Pvt. Ltd	Date:- 22 /08/2022	
Serial No.:- As per below sheet	P.O. No.:- 4511003730	P.O. Date :- 31.08.2021
Place: - M/s. Indian Immunologicals Limited., Survey No. 281-284 & 321, Biotech Park Phase III, Karakapatla Markook Mandal, Siddipet, Dist- Telangan-502281, India.	Project: KH08 block Viral Antigen Project.	
<b>Subject:- commissioning and qualification of manufacturing vessels at KH08 block.</b>		
Person Present Of Bright Pharma Mumbai, INDIA and M/s. Indian Immunological Limited. Karkapatla		
<b>Name / Signature(Bright Pharma)</b>	<b>Name / Signature(IIL)</b>	
Mr. Rahul Yevale  22-08-22	Mr. Madhukar.V  22-08-22	
	Mr. K. Sreenivasa Chari  22-08-22	
	Mr. Thrinath Kumar. K  22-08-22	
	Mr. Veerabhadra rao.CH  22-08-22	
	Mr. P. Ramakrishna  22-08-22	
	Mr. G. Balaji  22-08-22	

MOM points of Antigen Project	
MOM Points	Comments
Mr. Rahul Yevale. Visited to M/s. Indian Immunological Limited. karakapatla 01/06/2022 to 22/08/2022 for Installation and commissioning of process vessels in Antigen Project Block.	Ok
IQ Done for 17 Vessels (BSL3 / 07 Vessels) and (BSL2 / 10 Vessels)	Found Satisfactory.
OQ Done for 16 Vessels and found satisfactory.	Found Satisfactory.
All Process checked i.e. Semi Auto/Auto/SIP/PLT/Auxiliary checked and found satisfactory.	Found Satisfactory.
OQ pending for 01 Vessels from BSL2 / Inactivation Vessel	Due to cooling line not available
Inactivation Vessel 01 no's Angle Valve and Temperature sensor not working properly need to send Bright Pharma for rectification of issue.	Ok Bright will rectify the issue and send back to IIL.
Mixing Vessel 02 no's Charging hole clamp not fixing properly, need to send Bright Pharma for rectification of issue.	Ok Bright will rectify the issue and send back to IIL.
All Printers (15No's), pH and DO sensors Installed and handover to IIL persons.	OK
Replacement of 03 no's of Dot Matrix printers with laser jet Printers.	Ok, Bright will Replace the Printer, please send 03 no's