

DAIKIN AIRCONDITIONING INDIA PVT. LTD.

Customer Service Report

Service Branch : Hyderabad

Toll Free
1800-102-9300
1800-22-9300 (From MTNL/BSNL)

Type of Service : AMC Commissioning
Warranty Other

Chiller Model : UAA 0801 F 574 - 16
Serial Number : 26VP6000001

Nature of Complaint :

Commissioning of Air cooled chiller

Work Shooting and Works Carried out :

Commissioning has been done for air cooled chiller.
Checked and checked all the safety's found normal.
Loading and unloading of the chiller w.o.t.
nt.
d chiller ON/OFF condition parameters found normal
d that there is less load in plant so, not possible
e full load parameters we will check same once the
ON.

Remarks :

Chiller working under normal
attended over the chiller to
for beneficial use

Customer's Remarks :

Chiller related parameters are
checked over the chiller to nominal
Chiller checked load
to once parameter load
we will inform for full load
check.

Spares :

Y N

Reqd. Used

Y N

Reqd. Used

Y N

Reqd. Used

Service Engineer Name : Bhargav Reddy + Raju

Reporting Date & Time : 13-08-2021 @ 14:00

Job Completion Time : 18:30

Service Engineer Signature : [Signature]

Is Operational:

er	7.0	°C / °F	Discharge Temperature (close liquid injection if Centrifugal)	77.1	°C / °F
Water Temperature	16.1	°C / °F	Discharge Superheat	32.7	°C / °F
Water Temperature	7.0	°C / °F	Saturation Evaporator Temperature	2.4	°C / °F
Water Temperature		°C / °F	Saturation Condensing Temperature	39.7	°C / °F
Water Temperature		°C / °F	Liquid Line temperature (measure if reading not available on Display)		°C / °F