

# KANYAKA PARAMESHWARI ENGG, LTD, HYD

## COURTESY/INSTALLATION/SERVICING CALL REPORT

A	B
CUSTOMER NAME <u>M/s. INDIAN IMMI</u>	Ref.No ..... DT <u>25.01.2021</u>
ADDRESS- <u>UNOLOGICAL LTD.</u>	TRANSFORMER SR.NR. <u>KP.P. 0204 KVA 2000</u>
<u>HYDEKABAD (TS)</u>	MAKE <u>KPEL</u> YEAR OF MFG. <u>2021</u>
PERSON REPORTING <u>Mr./Mrs. VIDYA SAGAR S</u>	CALL CATEGORY: UNDER WARRANTY / <input checked="" type="checkbox"/>
PHONE NO: <u>9640395333</u>	OUT OF WARRANTY / Service
DETAILS OF COMPLAINT <u>POWER TRAN-</u>	ATTEND BY: <u>R. SUDHU</u>
<u>SFORMER 2000 KVA 02NO'S</u>	
<u>INSTALLATION WORK</u>	SIGNATURE OF CUSTOMER CARE MANAGER

C OBSERVATION	D WORK DONE
<u>Power transformer</u>	<u>Power transformer 2000</u>
<u>SL.NO:- KP-PT-0204</u>	<u>KVA 02 no's commission-</u>
<u>SL.NO:- KP-PT-0203</u>	<u>ing work Installation</u>
<u>Radiator Fitting, oil</u>	<u>work is completed</u>
<u>Filling and O.T.C</u>	<u>and O.T.C TO RTCC panel</u>
<u>TO RTCC panel conn-</u>	<u>connection work was</u>
<u>nection work</u>	<u>completed Power Trans-</u>
<u>RTCC panel setting</u>	<u>former also charged</u>
<u>Low set : 420V</u>	<u>Load also taken</u>
<u>Raise set : 400V</u>	<u>Three phase voltage</u>
<u>Voltage : 425V</u>	<u>RY = 426V</u>
<u>Tap no :- 03</u>	<u>YB = 425V</u>
<u>Time delay :- 60sec</u>	<u>BR = 426V</u>


DT. OF REPORTING <u>25.01.21</u> TIME <u>11:00am</u>	DT. OF COMPLETION <u>25.01.21</u> TIME <u>7:15pm</u>
--	--

E MATERIALS USED	F MATERIALS RETURNED
/	/

G

CUSTOMER REMARKS

CUSTOMER SIGNATURE WITH SEAL



4640395333

Rajana  
Servicing Engineer.  
for KANYAKA PARAMESHWARI ENGG, LTD.

8106846138

# KANYAKA PARAMESHWARI ENGG, LTD, HYD

## COURTESY/INSTALLATION/SERVICING CALL REPORT



A	B
CUSTOMER NAME <u>M/s. INDIAN IMM</u>	Ref.No. .... DT <u>25.01.2021</u>
ADDRESS- <u>UNOLOGICAL LTD.</u>	TRANSFORMER SR.NR. <u>KP-PT-0204 KVA 2000</u>
<u>HYDERABAD (TS)</u>	MAKE <u>KPEL</u> YEAR OF MFG. <u>2021</u>
PERSON REPORTING <u>Mr./Mrs. VIDYA SAGAR</u>	CALL CATEGORY: UNDER WARRANTY / <input checked="" type="checkbox"/>
PHONE NO. <u>9640395333</u>	OUT OF WARRANTY / Service
DETAILS OF COMPLAINT <u>POWER TRAN-</u>	ATTEND BY: <u>R. SUDHU</u>
<u>- FORMER 2000 KVA 02NO</u>	SIGNATURE OF CUSTOMER CARE MANAGER
<u>INSTALLATION WORK</u>	

C OBSERVATION	D WORK DONE
<u>Power Transformer</u>	<u>Power Transformer 2000</u>
<u>Sl. No:- KP-PT-0204</u>	<u>KVA 02no's Commission-</u>
<u>Sl. No:- KP-PT-0203</u>	<u>ing work. Installation</u>
<u>Radiator Fitting, oil</u>	<u>work is completed</u>
<u>Filling and O.T.C</u>	<u>and O.T.C TO RTCC panel</u>
<u>to RTCC panel conn-</u>	<u>connection work was</u>
<u>nection work</u>	<u>completed. Power Trans-</u>
<u>RTCC panel setting</u>	<u>former also charged</u>
<u>Low set 420V</u>	<u>Load also taken.</u>
<u>Raise set : 400V</u>	<u>Three phase voltage</u>
<u>Voltage : 425V</u>	<u>RY = 426V</u>
<u>Tap no :- 03</u>	<u>YB = 425V</u>
<u>Time delay :- 60sec</u>	<u>BR = 426V</u>

DT. OF REPORTING <u>25.01.21</u> TIME <u>11:00 AM</u>	DT. OF COMPLETION <u>25.01.21</u> TIME <u>7:00 PM</u>
---	---

E MATERIALS USED	F MATERIALS RETURNED
/	/

CUSTOMER REMARKS	G
------------------	---

 CUSTOMER SIGNATURE WITH SEAL	 Servicing Engineer. for KANYAKA PARAMESHWARI ENGG, LTD. <u>8106846138</u>
---	---