

Field Service Report

FSR Number: VERINBLRL047.021121.I.2		Dated: 02-11-2021	
		<input type="checkbox"/> AMC	<input checked="" type="checkbox"/> WARRANTY
		<input type="checkbox"/> POST WARRANTY	
Type of Service:		Product:	Power:
<input checked="" type="checkbox"/> I&C	<input type="checkbox"/> PM	<input type="checkbox"/> FAIL	<input type="checkbox"/> CORRECTIVE
<input type="checkbox"/> TRAINING	<input type="checkbox"/> TECH.	<input type="checkbox"/> COURTESY	<input type="checkbox"/> OTHER
Customer:	M/S. Indian Immunologicals Limited.	Engineer's Name:	RAMAN
Site Address:	Survey No: 281-284&321 ,Biotech Park Phase III, Karkapatla, Markook Mandal, Siddipet Dist, Telangana - 502281, India	Employee Code:	7059
Customer Contact:	MR.Peddi Reddy ; 9959050359	Phone Number:	7400086903
Date of Complaint:	2/11/2021	Call ID Number:	
Time of Complaint:	10:00	Region:	SEZ_HYDERABAD
Complaint/Fault Reported:	60KVA UPS I&C		
Reporting Date/Time:	2/11/2021	Manhours Idle/Stay:	hours minutes
Manhours Travelling:	2 hours 0 minutes	Manhours Onsite:	4 hours 0 minutes
		Time of Completion:	17:30
		Total Manhours:	6 hours 0 minutes
System Details			
	Model	Rating	Serial Number
1	HIPULSE U	60KVA	202102HU4844
2			
3			
4			
5			
6			
7			
8			
9			
10			
Observations / Comments / Recommendations / Suggestions / Work Done			
<p>Checked the UPS physical conditiona and all cables terminations found ok. Hipulse U model 60KVA UPS with Quanta SMF 12V/120AH-32no's - 2sets of Batteries (Batteries APS scope) Installation & Commissioning done sucessfully. UPS tested with no load at present Customer load not connected. Output Voltage : 405V, as per the customer requirement. Bypass Enabled</p>			
Spare Parts Recommendation			
	Part Code	Description	Quantity
1			
2			
3			
4			
5			
Service to be billed:		Total Price:	
Customer's Remark and Signature		Engineer's Remark and Signature	
The above job was carried out and completed to our satisfaction. The equipment is working satisfactorily. We agree to pay the charges as indicated.			
<p>For Queries, please contact our Customer Care Center T: 1800 208 6070 Vertiv Energy Private Limited</p>			