

**ERECTION & INSTALLATION
CERTIFICATE**

Client: M/s INDIAN IMMUNOLOGICALS
LTD

Location: RAKSHAPURAM, HYDERABAD

PO.NO :4511002936 DT.05/07/2019

ERECTION & INSTALLATION CERTIFICATE OF AMMONIA RECEIVER TANK

DATE: 13.12.2021

COUSTOMER NAME & ADRESS

: M/s INDIAN IMMUNOLOGICALSLTD
RAKSHAPURAM, HYDERABAD

THE FOLLOWING ITEMS ITEM ERCTED & INSTALLED TO YOUR SATISFACTION:

PARAMETERS:


- | | |
|---------------------|--|
| 1. ITEM DESCRIPTION | : Ammonia Receiver Tank of Size 915X6096LG |
| 2. MODEL/CAPACITY | : 4000L |
| 3. JOB/MSN No | : 051211420 |

THE ABOVE SYSTEM HAS BEEN HANDED OVER IS SATISFATTORY WORKING
CONDITION.

For FRICK INDIA PVT.LTD


ERECTION ENGINEER

Name
Designation
Customer signature

: S. M. M. M. M.
: ST. executive
: 

Submitted By:
Frick India Pvt.LTD
Faridabad



Equipment: SUPPLY OF Ammonia Receiver Tank



FRICK INDIA LIMITED

608, VI th Floor,
Swapnalok Complex,
92/93, S.D. Road,
Secunderabad - 500 003. (T.S.)
CIN : L74899HR1962PLC002618

Phone : 27813897, 66311695

E-mail : hyd@frick.co.in

Website : www.frickweb.com

Mobile : 9391051635

Date : 18.12.2021

To
The Manager (Engg Dept.)
M/s. Jordan Immunologicals Ltd
Gaechipowli - Hyderabad.

Dear Sir,

Sub: Ammonia H.P Receiver regarding:-

We have supplied, erected, pipeline and receiver fittings works completed for the above receiver.

H.P receiver tested with N₂ cylinders with 260 PSI pressure and holded for one day.

Vacuum also done the H.P receiver and filled ammonia & found it's okay.

We have also removed the old H.P receiver from the foundations before installing the new receiver.

Thanking you
Yours faithfully
for FRICK INDIA LTD

M. Muralidharan
M. MURALIDHARAN

Receiver replaced and
it is under observation.


18.12.21



AN ISO 9001:2015 CERTIFIED COMPANY

Regd. Office & Factory : 21.5 Km, Main Mathura Road, Faridabad - 121 003 (Hararyana)

Branches : Ahmedabad, Bangalore, Chandigarh, Chennai, Cochin, Jalandhar, Kolkata, Mumbai, New Delhi, Patna, Visakhapatnam.